



Republic of the Philippines  
**Leyte Normal University**  
 Tacloban City



Management System  
 ISO 9001:2015

www.tuv.com  
 ID: 910658608



**BIDS AND AWARDS COMMITTEE**

**SUPPLEMENTAL BID BULLETIN NO. 2**  
**Rehabilitation of HRDC Building**

11-10-21

This supplemental bid bulletin dated November 9, 2021 is being issued to amend provisions of the bidding documents for the project entitled Rehabilitation of the HRDC Building.

| <b>PROCUREMENT ACTIVITY</b>     | <b>FROM</b>   | <b>TO</b>  |
|---------------------------------|---|--|
| Rehabilitation of HRDC Building | ITB Clause 7.1<br>Sub-contracting is allowed for the following major work items:<br>1. Stage Lighting Effects System<br>2. Audio System | ITB Clause 7.1<br>Sub-contracting is allowed for the following major work items:<br>1. Stage Lighting Effects System<br>2. Audio System<br>Qualifications of a Light & Sound Sub-contractor for HRDC Project<br>1. Must present a proof or certification that he has at least two years experienced in light and audio system installation and operation.<br>2. Must be a certified installer of the equipment supplied. Those with certificate as designer on the audio system is a plus.<br>3. Must conduct a rigid training on each equipment operation and control.<br>4. Must conduct a rigid training on trouble shooting and repair to our LNU technician on equipment installed or supplied. |



Republic of the Philippines  
**Leyte Normal University**  
Tacloban City



Management  
System  
ISO 9001:2015



www.tuv.com  
ID: 910865608

|  |  |
|--|--|
|  | <p>5. Must provide at least 1 year warranty on the equipment supplied.</p> <p>For Main contractor</p> <ol style="list-style-type: none"><li>1. Additional specs for 1000A Air Circuit Breaker with 3 Phase GFCL, Enclosure must have basic parameter and indicator pilot light Green Red Yellow, analog/digital voltmeter per phase, Ammeter per line, Frequency meter.</li><li>2. ATS for the 350 kw generator must be floor standing and ACB type.</li><li>3. 350 kw generator includes mechanical louver.</li></ol> |
|--|--|

The foregoing shall form an integral part of the Bidding Documents. Any provision in the Bidding Documents inconsistent herewith is hereby amended, modified and suspended accordingly.

Prepared by:

**Leonizza N. Dimatahgal**  
BAC Secretariat

Noted by:

**Generoso N. Mazo, Ph.D.**  
BAC Chair